

 **ANALYTICAL REPORT****PREPARED FOR**

Attn: Tom Martiak
CSL Water Quality Warren
156 Mt. Bethel Road
Warren, New Jersey 07059

Generated 4/10/2025 4:32:57 PM

JOB DESCRIPTION

Spectrum Academy - Upper School - Lead/Copper

JOB NUMBER

630-107549-1

Eurofins Environment Testing Philadelphia, LLC

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Environment Testing Philadelphia, LLC Project Manager.

Authorization



Generated
4/10/2025 4:32:57 PM

Authorized for release by
Erin Dougherty, Project Administrator
Erin.Dougherty@et.eurofinsus.com
(215)355-3900

Compliance Statement

Analytical test results meet all requirements of the associated regulatory program (e.g., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis. Data qualifiers are applied to note exceptions. Noncompliant quality control (QC) is further explained in narrative comments. QC data that exceed the upper limits and are associated with non-detect samples are qualified but no further narration is needed since the bias is high and does not change a non-detect result. Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Coliform MCLs

· Based on the EPA primary drinking water standard MCL for total coliforms, a water supply is considered bacteriologically "SAFE" if no coliform bacteria are detected. To be considered "SAFE" your report should indicate "<1 cfu/100mL" or "NEG" for the coliform test. If you report indicates a positive result "POS" or a value greater than or equal to one, then your supply is "UNSAFE FOR DRINKING" contact your local health department.

Warranties, Terms, and Conditions

· Analyses for Field Parameters are performed by Eurofins Philadelphia field staff. Locations and certifications are identified on the Chain of Custody as follows:

ERF = field staff performs tests under NJ State certification # 02015.

VL = field staff performs tests under NJ State certification # 06005.

WG = field staff performs tests under NJ State certification # PA001, PA State certification # 48-01334.

H = field staff performs tests under NJ NELAP certification # PA093, PA NELAP certification # 46-05499.

· Test results meet all TNI or other applicable regulatory agency requirements, including holding times and preservation, unless otherwise indicated.

· The report shall not be reproduced, except in full, without the written consent of the laboratory

· All samples are collected as "grab" samples unless otherwise identified.

· Reported results related only to the samples as tested. Eurofins Philadelphia is not responsible for sample integrity unless sampling has been performed by a member of our staff.

· Eurofins Philadelphia is not responsible for sampling and/or testing omissions. Note that regulatory authorities may assess substantial fines for testing omissions. Please track your sample collection schedules and results on a regular basis (e.g. weekly, monthly, or quarterly) to ensure compliance.

· Eurofins' online data portal "TotalAccess" will provide you with real-time access to collection dates and testing results. Please contact Client Services for further information.

· The following personnel or their deputies have approved the results of the tests performed by Eurofins Philadelphia : Nicki Smith (Environmental Chemistry) and Jacqueline Gartner (Water Microbiology).



Case Narrative

Client: CSL Water Quality Warren
Project: Spectrum Academy - Upper School - Lead/Copper

Job ID: 630-107549-1

Job ID: 630-107549-1

Eurofins Environment Testing Philadelphia,

Job Narrative 630-107549-1

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable.

- Matrix QC may not be reported if insufficient sample is provided or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Receipt

The samples were received on 4/1/2025 3:00 PM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 2.2°C.

Metals

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Sample Summary

Client: CSL Water Quality Warren
Project/Site: Spectrum Academy - Upper School - Lead/Copper

Job ID: 630-107549-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
630-107549-1	UPPER KITCHEN	Drinking Water	03/31/25 12:46	04/01/25 15:00
630-107549-2	UPPER CAFE FOUNTAIN	Drinking Water	03/31/25 12:52	04/01/25 15:00
630-107549-3	UPPER GYM FOUNTAIN	Drinking Water	03/31/25 12:57	04/01/25 15:00

- 1
- 2
- 3
- 4
- 5
- 6
- 7

Client Sample Results

Client: CSL Water Quality Warren
 Project/Site: Spectrum Academy - Upper School - Lead/Copper

Job ID: 630-107549-1

Client Sample ID: UPPER KITCHEN

Lab Sample ID: 630-107549-1

Date Collected: 03/31/25 12:46

Matrix: Drinking Water

Date Received: 04/01/25 15:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	0.12		0.010	0.0023	mg/L		04/10/25 15:00	1	SAM2
Lead	ND		0.0010	0.00069	mg/L		04/10/25 15:00	1	SAM2

Client Sample ID: UPPER CAFE FOUNTAIN

Lab Sample ID: 630-107549-2

Date Collected: 03/31/25 12:52

Matrix: Drinking Water

Date Received: 04/01/25 15:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	0.011		0.010	0.0023	mg/L		04/10/25 11:17	1	SAM2
Lead	ND		0.0010	0.00069	mg/L		04/10/25 11:17	1	SAM2

Client Sample ID: UPPER GYM FOUNTAIN

Lab Sample ID: 630-107549-3

Date Collected: 03/31/25 12:57

Matrix: Drinking Water

Date Received: 04/01/25 15:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	0.045		0.010	0.0023	mg/L		04/10/25 11:04	1	SAM2
Lead	ND		0.0010	0.00069	mg/L		04/10/25 11:04	1	SAM2

Accreditation/Certification and Definitions Summary

Client: CSL Water Quality Warren
 Project/Site: Spectrum Academy - Upper School - Lead/Copper

Job ID: 630-107549-1

Laboratory: Eurofins Lancaster Laboratories Environment Testing, LLC

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
New Jersey	NELAP	PA011	06-30-25

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
1C	Result is from the primary column on a dual-column method.
2C	Result is from the confirmation column on a dual-column method.
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
MRL	Method Reporting Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
SDL	Sample Detection Limit
SDL	Sample Detection Limit
SDL	Sample Detection Limit
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count



Method Summary

Client: CSL Water Quality Warren
Project/Site: Spectrum Academy - Upper School - Lead/Copper

Job ID: 630-107549-1

Method	Method Description	Protocol	Laboratory
200.8	Metals (ICP/MS)	EPA	ELLE
Non-Digest Prep	Preparation, Non-Digested Aqueous Metals	EPA	ELLE

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

ELLE = Eurofins Lancaster Laboratories Environment Testing, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300





Environment Testing Philadelphia

795 Horsham Road Horsham, PA 19044 Phone : 215-355-3900

Client/Act. No. AS 6076

Address 156 Mt. Benger Rd

City/State/zip Warrington, PA 18982

Phone/Fax 07059

Client Contact: e-mail:

PROJECT

Collection

Military Time

BARMP

Matrix Code

Total

Number of Containers

FIELD ID

Date

Matrix Code

BARMP

Number of Containers

Field pH, Temp (°C), DO, Cl2, Cond, etc.

ANALYSIS REQUESTED

DI Water

HCl # NH4Cl # MeOH

Unpreserved

NaOH

H2SO4

HNO3

NaOH/Znacetate

Na2S2O3

Ascorbic/HCl Vials # HCl Vials

DW: DRINKING WATER

GW: GROUND WATER

WW: WASTEWATER

SO: SOIL

SL: SLUDGE

OIL: OIL

SOL: NON SOIL SOLID

MI: MISCELLANEOUS

X: OTHER

107549

Loc: 630

630-107549 Chain of Custody



CHAIN OF CUSTODY Page 9 of 10

Bill to/Report to (if different)

of

FIELD ID

Date

Matrix Code

BARMP

Number of Containers

FIELD ID

Date

Matrix Code

BARMP

Number of Containers

SAMPLED BY: (Name/Company)

TAT: STANDARD (10 DAY)

Report Format: Standard NJ-RDD SRP-RDD

Initials

Date/Time:

Field Parameters Analyzed By:

Please call for pricing and availability for rush (<10 day) turnaround and for all but standard reporting format

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW. USE FULL LEGAL SIGNATURE, DATE AND MILITARY TIME (24 HOUR CLOCK, IE, 8AM IS 0800, 4 PM IS 1600)

RECEIVED BY SAMPLER

DATE TIME

RECEIVED BY

DATE TIME

DATE TIME

DELIVERY: FEETP COURIER CLIENT UPS FEDEX OTHER

Custody Seal Number

RECEIVED BY

DATE

RECEIVED BY

DATE TIME

DATE TIME

COMMENTS:

Rec'd Temp.: 2.2°C Initials: ASJ Ice Y/DN Location: 544

RECEIVED BY

DATE

RECEIVED BY

DATE TIME

DATE TIME

Hazardous: yes / no

1 2 3 4 5 6 7

Eurofins Environment Testing Philadelphia,

795 Horsham Road
Horsham, PA 19044-0962
Phone: 215-355-3900

Chain of Custody Record



Client Information (Sub Contract Lab)		Sampler: N/A		Lab PM: Dougherty, Erin		Carrier Tracking No(s): N/A		COC No: 630-17290.1		
Client Contact: Shipping/Receiving		Phone: N/A		E-Mail: Erin.Dougherty@et.eurofinsus.com		State of Origin: New Jersey		Page: Page 1 of 1		
Company: Eurofins Lancaster Laboratories Environm				Accreditations Required (See note): NELAP - New Jersey				Job #: 630-107549-1		
Address: 2425 New Holland Pike.		Due Date Requested: 4/14/2025		Analysis Requested				Preservation Codes: -		
City: Lancaster		TAT Requested (days): N/A								
State, Zip: PA, 17601		PO #: N/A								
Phone: 717-656-2300(Tel)		WO #: N/A								
Email: N/A		Project #: 63002498								
Project Name: Spectrum 360, Upper School - Lead/Copper		SSOW#: N/A								
Site: N/A										
Sample Identification - Client ID (Lab ID)		Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Field Filled Sample (Yes or No)	Perform MS/MSD (Yes or No)	200.0_S/DWA/MTL_NO_Prepare Cu & Pb only	Total Number of containers	Special Instructions/Note:
Preservation Code										
UPPER KITCHEN (630-107549-1)	3/31/25	12:46 Eastern	G	Drinking Water		X			1	
UPPER CAFE FOUNTAIN (630-107549-2)	3/31/25	12:52 Eastern	G	Drinking Water		X			1	
UPPER GYM FOUNTAIN (630-107549-3)	3/31/25	12:57 Eastern	G	Drinking Water		X			1	
Note: Since laboratory accreditations are subject to change, Eurofins Environment Testing Philadelphia, LLC places the ownership of method, analyte & accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/tests/matrix being analyzed, the samples must be shipped back to the Eurofins Environment Testing Philadelphia, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Environment Testing Philadelphia, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Environment Testing Philadelphia, LLC.										
Possible Hazard Identification						Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)				
Unconfirmed						<input type="checkbox"/> Return To Client <input type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For _____ Months				
Deliverable Requested: I, II, III, IV, Other (specify)			Primary Deliverable Rank: 1			Special Instructions/QC Requirements:				
Empty Kit Relinquished by:				Date:		Time:		Method of Shipment:		
Relinquished by: <i>[Signature]</i>		Date/Time: 4/1/25 1500		Company: <i>[Signature]</i>		Received by:		Date/Time:		
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:		
Relinquished by:		Date/Time:		Company:		Received by: <i>[Signature]</i>		Date/Time: 4/2/25 10:10		
Custody Seals Intact: <i>[Signature]</i> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>		Custody Seal No.:				Cooler Temperature(s) °C and Other Remarks: R= 0.3 C= 0.2 2.2°C				